*** Historical View ** Note: In the process of enhancing our systems, we are transitioning data to a new Product iQ data view. This data is being verified with the "Historical" view for accuracy. Once the data is confirmed, the "Historical" view will be discontinued. During this transition, you may encounter duplicate entries or missing/outdated data. For queries during this interim period, please visit our Historical View FAQs or contact our Customer Service.*

Smoke-automatic Fire Detector Accessories

COMPANY
Simplex Time Recorder Co
6 TECHNOLOGY PARK DR
WESTFORD, MA 01886 United States

S2467

Alarm relay modules Model(s) *2098-9737, 2098-9739, 2098-9827, 4098-9841, 4098-9822, 4098-9860*

Extension boxes Model(s) *4098-9847, for use with listee's model 4098-9714 analog smoke detector and models 4098-9789, -9791, -9792, -9793 bases.*

Full spectrum light shield Model(s) *4098-9867*

In-duct adapters Model(s) *4098-9819, 4098-9824, 4098-9852, 4098-9853*

remote alarm indicator Model(s) *2098-9744, 2098-9808, 4098-9830*

remote alarm indicator with test switch Model(s) *2098-9806, 4098-9834*

remote power/alarm indicator with test switch Model(s) *2098-9805, 4098-9835*

Smoke detector accessories Model(s) *553-533*

Smoke detector data readers Model(s) *4098-9839, not to be used to indicate actual sensitivity values.*

Smoke detector guards Model(s) *4098-9838, for use with listee's model 4098-9714 analog smoke detector head and models 4098-9789, -9791, -9792, -9793 bases, for ceiling mount use only, smoke sensitivity of model 4098-9714 smoke detector head when installed in conjunction with model 4098-9838 detector guard is reduced to a range of 0.5 to 1.5 percent per foot obscuration with a fire alarm control panel alarm threshold setting of 15 to 42 delta.*

Smoke detector guards Model(s) *4098-9846, for use with listee's model 4098-9714 analog smoke detector and models 4098-9789, -9791, -9792, -9793 bases.*

Weatherproof enclosures Model(s) *4098-9845*

Trademark and/or Tradename:

Last Updated on 2024-10-09

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings).

2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2026 UL LLC."